



Report No: - C &I/ 21052


Date: -06.03.2021

## TEST REPORT


Name of Customer	M/s Global Public School Indravihar, Talwandi, Kota
Reference No.	Letter, Dated – 05.03.2021
Lab. Job No.	21052
Sample Receipt Date	05.03.2021
Name of Work	---
Material/ Material Identification	Water Sample
Make/Source	Drinking Water
Date of Testing	06.03.2021

## TEST RESULTS

S.No.	Parameters	Results	Permissible Limits As per IS 10500- 2012(Max. Limits)	Test Method
1.	pH Value	6.90	6.5-8.5	IS-3025-P(11):1983
2.	Turbidity (NTU)	Nil	1.0	IS-3025-P(10):1982
3.	Taste	Agreeable	Agreeable	IS-3025-P(8):1984
4.	Colour	APHA	5	IS-3025-P(4):1987
5.	Odour	Agreeable	Agreeable	IS-3025-P(5):1983
6.	T.D.S.: (ppm)	150	500	IS-3025-P(16):1984
7.	Total Hardness (mg/lit.)	120	200	IS-3025-P(21):2009
8.	Acidity (mg/lit.)	6	----	IS-3025-P(22):1986
9.	Alkalinity (mg/lit.)	20	200	IS-3025-P(23):1986
10.	Chloride (mg/lit.)	27	250	IS-3025-P(32):1988
11.	Sulphate (mg/lit.)	30	200	IS-3025-P(24):1986
12.	Calcium (mg/lit.)	11.	75	IS-3025-P(40):1991
13.	Magnesium (mg/lit.)	8	30	IS-3025-P(46):1994

Checked by:   
 Principal



  
 Authorized Signatory

Note: -   
 Global Public School  
 Indravihar, Talwandi, KOTA-5

1. The test result refers only to the samples received in the Laboratory.
2. This report shall not be reproduced except in full without written approval from C&I SYSTEMS Laboratory.
3. Any discrepancy in test results should be reported within 15 days from the date of report.
4. C&I SYSTEMS Laboratory shall not in any way be involved in any action following the interpretation of test results.
5. This report is not valid any Legal proceeding.

End of Report  
 Page 1 of 1

For GLOBAL PUBLIC SCHOOL



Authorized Signatory